



**WASHTENAW COUNTY  
FINANCE DEPARTMENT  
Purchasing Division**

P. O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645  
Phone (734) 222-6760, Fax (734) 222-6764  
www.purchasing.ewashtenaw.org

September 18, 2014

**Addendum #1**

RFP No.                      **6799**

Title:                         **PARKER MILL GRIST AND CIDER MILLS  
REROOFING PROJECT**

Due Date Revised: **Tuesday, September 23, 2014 at 3:00PM**

This addendum is generated to clarify the items identified below and shall become part RFP #6799.

Item No. 1

The bid opening due date has been advanced from September 30, 2014 to the new date as indicated above.

Item No. 2

For Clarification.

The use of pneumatic nail guns is allowed for nailing shingles. However, the following conditions must be complied with:

1. Stainless steel nails meeting the specifications must be used and not staples.
2. The proper pressure on the gun must be set as to not split or penetrate the shingle.

Acknowledgement of receipt of this addendum by the bidder must be recorded on page P1 of the submitted bid document proposal. Failure to submit acknowledgement of addendum could result in disqualification of bid.

END OF ADDENDUM #1

***Angela O. Perry***  
***Purchasing Manager***

cc: RFP #6799