



**WASHTENAW COUNTY
FINANCE DEPARTMENT**

Purchasing Division

P. O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645
Phone (734) 222-6760, Fax (734) 222-6764
www.purchasing.ewashtenaw.org

May 5, 2011

Addendum #1

RFP No.

6613

Title:

Diesel Generator for WCRC

Due Date:

Thursday, May 11, 2011 at 4:00PM

This addendum is generated due to various vendor questions.
Responses are attached.

Crystal A. Wake, CPPB, C.P.M.
Senior Buyer

cc: RFP 6613

QUESTIONS & ANSWERS

RFP #6613

- Q1. List of approved generators “Generac” did not make the list, should we offer as an alternate or can you approve “Generac” before bids are submitted?**

Manufacturer of generator must meet the specifications as stated in the proposal document as well as the Made in America standard.

- Q2. At the meeting it was mentioned no work on Fridays, but shutdown can be planned for a Friday. Is this correct and will we have access the day of shutdown to the 200ATS that is being removed?**

The switch over work shall be completed in two phases: work on Friday for building “C” and “D”, and office building on Saturday.

- Q3. In the Notes it states that entrance of conductors shall be from beneath generator, does this mean Washtenaw County will be cutting the pad for access or will it be approved to somehow come in the side of the generator?**

With the location change and close proximity all conduit shall remain above the surface.

- Q4. Who is responsible for the disconnection and removal of existing 100kw generator?**

The contractor is responsible for the disconnect of the generator. The Owner shall be responsible for its removal.

- Q5. The pad you want us to utilize appears to be too small for the generator that is specified due to the 48 hour fuel tank?**

Upon approval of the new generator, final measurements will be made and modifications to the pad shall be completed by the Owner.

- Q6. What other rules and requirements must be followed?**

OSHA AND MIOSHO requirements must be met. Parks does not have any other requirements above OSHA and MIOSHA aside what is already mentioned in the bid documents.