

[Type text]



**WASHTENAW COUNTY
FINANCE DEPARTMENT**

Purchasing Division

P. O. Box 8645, 220 N. Main, Ann Arbor, MI 48107-8645
Phone (734) 222-6760, Fax (734) 222-6764
www.purchasing.ewashtenaw.org

May 24, 2011

Addendum #1

RFP No. 6614

Title: Fire Detection & Alarm System Services

Due Date: Thursday, June 2, 2011 at 4:00PM

This addendum is generated due to various vendor questions and clarification on pricing requirements.

1. Questions and Responses (see attached).
2. Clarification on pricing requirements on page 16. Please replace original page 16 with attached page 16 when submitting bid proposal.

Addendum MUST be included in bid proposal submission. Failure to submit addendum could result in disqualification.

Crystal A. Wake, CPPB, C.P.M.
Senior Buyer

cc: RFP 6614

ADDENDUM #1

QUESTIONS & RESPONSES

RFP #6614

Q1. Are all Duct Detectors accessible without lifts?

To the best of our knowledge All Duct Detectors should be reasonably accessible. If not, vendor is responsible to supply all necessary equipment to access and complete inspection requirements.

Q2. Does the proposal require sprinkler heads checked for compliance?

In county buildings with sprinkler systems selected vendor shall be responsible to identify sprinkler head manufacturer and model to insure heads have not been recalled or obsolete.

Q3. How many secured buildings requiring background checks?

Vendor selected per proposal will be required as part of vendor set up to pay for, submit all requested information and pass background checks to service ANY county building.

ADDENDUM #1

REPLACEMENT BID SHEET

Site Address	Details	Qty.	Frequency	Each	Total
2201 Hogback & 4133 Wash.	Fire Sprinkler System (Test and Inspect)				
	Wet Sprinkler Inspection (Includes one riser, tamper and flow) One Walk-through yearly.	1	Quarterly	\$	\$
		1	Annually	\$	\$
	Dry Pipe Sprinkler System	1	Quarterly	\$	\$
	Stand Pipe	2	5 Year	\$	\$
	Fire Alarm Detection System				
	Vanguard MPC 6000	1	Quarterly	\$	\$
	Additional Panel Remote Panel	1	Quarterly	\$	\$
	Smoke Detector (Test/Inspect)	170	Quarterly	\$	\$
	Smoke Detector Sensitivity Test	170	2 Year	\$	\$
	Duct Smoke Detector – Analog	28	Quarterly	\$	\$
	Heat Detector	31	Quarterly	\$	\$
	Pull Station	35	Quarterly	\$	\$
	Waterflow Switches	4	Quarterly	\$	\$
	Supervisory Switches	4	Quarterly	\$	\$
	Door Holders	2	Quarterly	\$	\$
	Audio/Visual Unit	23	Quarterly	\$	\$
	Low/Hi Pressure	4	Quarterly	\$	\$
	Kitchen System	1	Quarterly	\$	\$

ANNUAL TOTAL FOR THIS LOCATION

\$ _____

312 W. Huron	Fire Sprinkler System (Test and Inspect)			Each	Total
	Wet Sprinkler Inspection (Includes one riser, tamper and flow)	1	Annual	\$	\$
	Additional Riser (Includes one riser, tamper and flow)	1	Annual	\$	\$
Fire Alarm Detection System					
	Edwards Fire Alarm Control Panel Hardwire Fire Alarm Panel (17-32 Zone)	1	Annual	\$	\$
	Smoke Detector (Test/Inspect)	53	Annual	\$	\$
	Smoke Detector Sensitivity Test	53	2 Year	\$	\$
	Duct Smoke Detector – Analog	2	Annual	\$	\$
	Pull Station	7	Annual	\$	\$

ANNUAL TOTAL FOR THIS LOCATION

\$ _____